

CITY OF WOOD RIVER WWTF COMBINED SEWER OVERFLOW REPORT

Date	CSO MGD MGD	CSO TSS MG/L	CSO BOD MG/L	CSO FECAL #/100 ML	EST. RAIN hrs.	EST. C.S.O. Hrs.	PRECIPITATION
							inches
8/1/2016							0.07
8/2/2016							0.02
8/3/2016	0.31	76	43	7,150,000	2.50	1.50	0.63
8/4/2016							0.00
8/5/2016	1.98	40	15	300,000	2.00	2.00	1.50
8/6/2016							0.03
8/7/2016							0.00
8/8/2016							0.00
8/9/2016							0.00
8/10/2016							0.00
8/11/2016							0.00
8/12/2016	0.93	144	44	1,053,333	3.50	2.50	0.00
8/13/2016							1.34
8/14/2016	0.05	47	42	8,800,000	2.00	1.25	0.00
8/15/2016	1.84	167	42	5,700,000	10.00	8.00	2.30
8/16/2016	0.04	134	62	10,600,000	1.00	1.00	0.90
8/17/2016							0.01
8/18/2016							0.00
8/19/2016							0.00
8/20/2016							0.00
8/21/2016							0.00
8/22/2016							0.00
8/23/2016							0.00
8/24/2016							0.04
8/25/2016							0.00
8/26/2016							0.00
8/27/2016	0.45	168	26	2,200,000	1.50	1.25	0.00
8/28/2016							1.00
8/29/2016							0.00
8/30/2016							0.00
8/31/2016	1.73	220	114	19,600,000	2.50	3.00	0.11
Minimum	0.04	40	15	300,000	1.00	1.00	0.00
Maximum	1.98	220	114	19,600,000	10.00	8.00	2.30
Total	7.33	996	388	55,403,333	25.00	20.50	7.95
Average	0.92	125	49	6,925,417	3.13	2.56	0.26