

CITY OF WOOD RIVER WWTF COMBINED SEWER OVERFLOW REPORT

Date	CSO MGD	CSO TSS	CSO BOD	CSO FECAL	EST. RAIN	EST. C.S.O.	PRECIPITATION
	MGD	MG/L	MG/L	#/100 ML	hrs.	Hrs.	inches
11/1/2016							0.00
11/2/2016	3.50	436	119	2,850,000	8.50	3.00	0.00
11/3/2016							2.70
11/4/2016							0.00
11/5/2016							0.00
11/6/2016							0.00
11/7/2016							0.00
11/8/2016							0.15
11/9/2016							0.03
11/10/2016							0.00
11/11/2016							0.00
11/12/2016							0.00
11/13/2016							0.00
11/14/2016							0.00
11/15/2016							0.00
11/16/2016							0.00
11/17/2016							0.00
11/18/2016	0.15	346	156	9,400,000	2.75	1.00	0.00
11/19/2016							0.27
11/20/2016							0.00
11/21/2016							0.00
11/22/2016							0.00
11/23/2016							0.13
11/24/2016							0.00
11/25/2016							0.00
11/26/2016							0.00
11/27/2016							0.00
11/28/2016	0.70	140	86	7,500,000	7.00	4.00	0.13
11/29/2016							0.51
11/30/2016							0.00
Minimum	0.15	140	86	2,850,000	2.75	1.00	0.00
Maximum	3.50	436	156	9,400,000	8.50	4.00	2.70
Total	4.35	922	361	19,750,000	18.25	8.00	3.92
Average	1.45	307	120	6,583,333	6.08	2.67	0.13